



## TYPICAL INSPECTIONS AND FREQUENCIES

These inspections are not performed by the Fire Department, but by a contractor of your choosing. It is important to verify that the contractor is performing the inspection or testing to a listed, NFPA standard. This list is not exhaustive and is meant as a guide only.

### NFPA 25

- Fire Suppression System – annually
- Internal Pipe inspection – every 5 years
- Gauge replacement – every 5 years
- Fire Department Connection / Standpipe Hydrostatic Test – every 5 years
- Fire Pump – annually
- Fire Hose – annually
- Standpipes – annually
- Private Fire Hydrants – annually
- Flow Testing – every 5 years

### NFPA 72

- Fire Alarm – annually

### NFPA 80

- Fire Dampers – every 4 years
- Fire Rated Roll-up doors, Fire Doors / Fire Shutters / Fire Windows - annually

### NFPA 17

- Spray Booth Extinguishing Systems – annually or when discharged

### NFPA 10

- Fire Extinguishers – annually or when discharged

### NFPA 96

- Restaurant Hood Suppression System – every 6 months

### NFPA 110

- Emergency Standby Power Systems (generators) – as manufacturer recommends, monthly and annually